

Visual Display & Bulletin Boards

1. Porcelain enamel face sheet should be used for accommodating projection.
2. Verify with end user the type of visual display and bulletin board (chalk boards, white boards, and smart boards).

Toilet Partitions

1. Toilet partitions will be either floor supported-overhead braced, or floor and ceiling supported. Wall Hung Urinal Screens will have integral wall mounting flange, or continuous wall mounting bracket mounted to solid blocking in the wall.

Signs

1. *Verify campus signage requirements with PM. Consultant is required to specify all life safety signage as required by UM System currently adopted codes.*
2. All signage must meet current ADA Standards.
3. Consultant is responsible for room related, or code compliant signage, this typically does not include way-finding or branding signage. Verify with PM. *(At MU all interior signs are provided and installed by owner, including code and room number/identification signage.)*

Exterior Signs

1. Design consultant is to coordinate with PM for exterior signage requirements for each campus.

Toilet & Bath Accessories

1. Design consultant is to coordinate with Facilities Operations for each campus to determine standard equipment and accessories.
2. Design consultant is responsible for all other accessories and components including, but not limited to; grab bars, hand dryers, mirrors, curtain rods, shower seats, soap dishes, insulation kits, feminine hygiene dispensers, and other.
3. Electric hand dryers and hands free operating mechanisms for water closets, urinals, and lavatories shall be used. Verify with PM if paper towel dispenser can be used in lieu of electric hand dryer.

Fire Protection

1. *Facilities shall be designed and constructed to meet the fire protection requirements as defined by currently adopted UM codes and standards.*
2. *A five-pound ABC multipurpose fire extinguisher, provided by the Owner located by Consultant, will be provided in each laboratory room, and in other locations as required by current adopted UM codes and standards.*
3. *Fire extinguisher cabinets will be included in Class A corridors. Cabinets may be recessed or semi-recessed models. Fire hoses will not be provided; however, standpipes and standard two and one half inch (2-1/2") fire department connections are required.*
4. *Emergency showers and eye-washers will be provided as required. Floor drains will not be provided at the emergency showers, verify with PM.*

END OF SECTION